

EAST CAROLINA UNIVERSITY

Health Sciences Campus

Potable Water & Fire
Protection System

Utility Condition Assessment

May 12, 2017

TABLE OF CONTENTS

SECTION 1 OVERVIEW

| | |
|---|---|
| Introduction | 1 |
| Costs Overview | 1 |
| Current Replacement Value | 1 |
| Total Renewal Costs..... | 2 |
| Methodology..... | 2 |
| Approach to Lifecycle Calculation | 2 |

SECTION 2 SYSTEM FINDINGS

| | |
|----------------------|---|
| Description | 7 |
| Recommendations..... | 8 |

SECTION 3 CONDITION ASSESSMENT DEFINITIONS 13

SECTION 4 COST SUMMARIES AND TOTALS

| | |
|--|----|
| Renewal Costs Matrix | 21 |
| Nonrecurring Project Costs | 22 |
| Recurring Component Replacement Costs..... | 23 |

SECTION 5 PROJECT DETAILS..... 26

SECTION 6 ASSET COMPONENT INVENTORY..... 37

SECTION 7 SYSTEM PHOTOLOG..... 41

UTILITY CONDITION ASSESSMENT

SECTION 1

OVERVIEW

OVERVIEW

Introduction

The Brody School of Medicine at East Carolina University (ECU) is on the Health Sciences Campus (HSC), west of downtown Greenville, and was started in the late 1970s/early 1980s. The campus is between about 75 feet (Brody building) and 25 feet above sea level (retention pond northwest of the Dental School) in an area of slightly sloping coastal plain upland from the Tar River floodplain. The south side of campus is relatively flat, with a gradual downslope to the north. Because of this slightly sloping terrain, extensive mechanical pumping is not required to provide adequate water pressures around campus.

Both potable water and fire water are supplied to the campus by the same city water mains via the Central Utility Plant. Potable or domestic water is distributed by 8 inch ductile iron water pipe to each building through the central plant utility tunnel. The only buildings with service-specific water meters are the Leo Jenkins Cancer Center and Warren Life Sciences.

Fire sprinkler service is provided to each building through a central distribution system generally located in the utility tunnel. A 125 hp fire pump provides ample supply and pressure for the fire sprinkler service of all connected buildings. This pump is located in room 113 of the HSC Central Utility Plant, along with the fire pump controller, jockey pump, and the two domestic water pumps with variable frequency drives. Fire protection sprinkler water piping is primarily routed through the utility tunnel and is connected to the individual buildings from the tunnel using buried line construction. Outside of the tunnel on campus are some dedicated branch fire mains and connections supplied from the larger 8 inch and 10 inch city supply lines supporting some individual facilities and both city and university owned fire hydrants.

The Brody building has a separate dedicated fire pump located in room GW58A. This 100 hp fire pump and controller were upgraded in 2012. The pump is not included in this report, as it was assessed in 2016 as part of the Facility Condition Assessment for the building.

Costs Overview

Current Replacement Value

The estimated cost in current dollars to replace the potable water and fire protection system is \$1,700,000. This is not a construction estimate or a detailed take-off but rather an estimate of replacement with like components. It does not include any fire protection in the individual buildings previously inspected by ISES engineers. This was covered in the Facility Condition Assessment reports for those buildings.

Total Renewal Costs

The estimated renewal costs for the potable water and fire protection system total \$703,743. The dual potable/domestic water pump system and variable frequency drives are recommended for lifecycle replacement. The potable/domestic water pipe within the first 350-375 linear feet of the original tunnel will also require replacement, and the installation of a new fire service connection for Leo Jenkins Cancer Center is recommended, as is a new secure post indicator valve for the line running to Vidant Hospital. Also replace the water valves and post indicator valve for the Pediatrics/Biotechnology outside vault.

Methodology

Data collected during inspections conducted on March 8 and 9, 2017 have been used to generate this utility infrastructure report. The goal was to produce a single campuswide potable water and fire protection system report with recommendations developed by ISES engineers. The assessments and estimates are based solely on visual and nondestructive observations, discussions with university personnel, and a review of existing drawings and previous engineering reports, such as the September 2014 *HSC Utilities Master Plan, Phase One and Two* (updated in October 2014) and the Affiliated Engineers, Inc. April 19, 2017 draft *ECU Health Sciences Campus – Utility Tunnel Evaluation* report. Nonstandard and/or additional inspection procedures and methods, along with engineering design support, may be necessary to fully define the specific costs and scope to renew various infrastructure utility asset components.

Approach to Lifecycle Calculation

Each component of the potable water and fire protection system has a quantifiable industry standard expected lifecycle. Information related to system performance was reviewed to determine trends that might affect that lifecycle and the future safety, reliability, and efficiency of the system. The table below shows the expected useful, reliable life of typical system components.

Table 1: Average Expected Useful Life

| COMPONENT | TYPE | USEFUL LIFE (YEARS) |
|---------------------------|-------------------|---------------------|
| Potable water supply line | PVC or plastic | 50 |
| Potable water supply line | Ductile iron | 75 |
| Potable water supply line | Cast-iron | 75 |
| Fire hydrant | Cast-iron | 65 |
| Fire pump | 125 hp, 1,000 GPM | 25 |
| Domestic water pump | 15 hp, electric | 20 |

| COMPONENT | TYPE | USEFUL LIFE (YEARS) |
|--------------------------|-------|---------------------|
| Variable frequency drive | 15 hp | 12 |

Source Data: ASHRAE, BOMA, Hartford Ins. Co., ISES Database

The realization of the full expected useful life preserves the original capital investment strategy while accelerated depreciation results in premature expenditure of resources. It should be emphasized that expected useful life values are averaged forecasts based on components that are properly maintained and operated without frequent and/or severe operating conditions. Chronological age is not the primary determinant of service life. In many instances, there is ample evidence of components operating well beyond predicted useful life values. This is why it is important to modify these values based on actual conditions, service history, operating conditions, installation environment, and actual field performance.

In addition, system components reaching the predicted endpoint of expected useful life do not necessarily cease to function. What does occur is a downward trend toward loss of service reliability, a potential increase in maintenance costs, and potential loss of water supply or fire protection support if a major supply line has a failure.

It is important to note that utility infrastructure assets normally encompass more than just a single component and will, in most situations, represent a section or group of materials, i.e. linear footage of installed piping systems. The majority of these systems will continue to operate reliably and safely beyond the ten-year planning horizon of this assessment. However, beyond the next ten years, it will be necessary to reinspect the systems to ensure that they continue to operate reliably.

UTILITY CONDITION ASSESSMENT

SECTION 2

SYSTEM FINDINGS

SYSTEM FINDINGS

Description

The potable water and fire protection system appears to be properly sized and in overall good condition. This is due in great measure to the operating age of the majority of the system. There are no indications of a significant accumulation of deferred maintenance. Most of the main water supply loop and fire protection water lines were installed around 1980 or later, making them almost 40 years old, and none are nearing the end of their expected service life. Typically, the distribution branches and/or building services were constructed around the same time as the buildings they supply.

The combined potable water and fire protection system consists of approximately 9,000 linear feet of piping (approximately 1.7 miles) ranging from 4 to 10 inches in diameter. Of this piping, 4,995 linear feet of it is for potable water distribution and 3,975 linear feet for fire protection water. These lines generally connect to and receive water from the larger 10 inch municipal supply lines running through the center of the HSC between Heart Drive and West Fifth Street or the 8 inch line running west of Moye Boulevard to a connection with the 10 inch line running through the campus proper. Overall, the campus potable water and fire protection system is a small, partially looped system within a much larger municipal loop with isolation valves to permit isolation of a section of campus line or an area of campus with minimal service interruption. Most of the campus buildings are fed from campus water mains and are not metered, making specific facility water losses impossible to determine unless directly observed. The following table is an estimate of the potable water and fire protection system components that serve the HSC.

Table 2: Summary of Potable Water and Fire Protection System Components

| MATERIALS | QUANTITY | UNITS | ESTIMATED INSTALL DATE |
|---------------------------|-------------|-------------|------------------------|
| 4 inch water supply pipe | 3,870 | Linear feet | 1980-2010 |
| 6 inch water supply pipe | 970 | Linear feet | 1980-2010 |
| 8 inch water supply pipe | 75 | Linear feet | 1980-2010 |
| 10 inch water supply pipe | 80 | Linear feet | 1980-2010 |
| 6 inch fire water line | 445 | Linear feet | 1980-2010 |
| 8 inch fire water line | 2680 | Linear feet | 1980-2010 |
| 10 inch fire water line | 850 | Linear feet | 1980-2010 |
| Fire hydrants | 10 | Each | 1980-2010 |
| Fire pump | 125 | Horsepower | 2005 |
| Domestic water pump | 2 x 15 = 30 | Horsepower | 2005 |
| Variable frequency drive | 2 x 15 = 30 | Horsepower | 2005 |

There are approximately 25 campus fire hydrants of various ages and conditions. Of these, 15 are owned by the city and ten appear to be owned by the university. Of those ten, eight appear to have been installed in the last five or six years. The hydrants are flushed routinely, and the campus pressure is adequate and satisfactory. All of the hydrants are in good condition and should outlast the scope of this assessment.

In 2016, Affiliated Engineers inspected the tunnel water piping where the first 350 feet of original 8 inch mechanical joint-ductile iron potable water pipe experienced a significant leak that resulted in a major domestic water outage on campus. Mechanical joint piping is normally reserved for underground piping due to the joint design having a leak allowance; when installed underground, the piping is locked into place from soil friction and weight. Movement in the pipe in the tunnel resulted in leakage at multiple mechanical joints and failure at one joint. The failed joint was repaired with flanged piping. Affiliated Engineers evaluated all of the piping in the tunnel and provided recommendations to address the 8 inch mechanical joint-ductile iron domestic/potable water piping. The newer tunnel piping has flanged joints and does not appear to have the same problems as the original 350 foot installation.

Recommendations

Based on the relatively good condition and young age of the main pipe network, none of the linear assets of the potable and fire water supply are expected to require general lifecycle replacement. However, the two 15 hp domestic pumps and their variable frequency drives in room 113 of the Central Utility Plant are expected to reach the end of their lifecycles within the next ten years and should be replaced.

Regarding the problematic oldest tunnel piping, of the options presented by Affiliated Engineers, ECU has chosen to replace the 350-375 feet of piping with mechanical joint fittings with a new domestic water pipe routed above the existing chilled water piping in the tunnel. The new line will be constructed in the original section of the tunnel and sized to accommodate anticipated future expansion. The existing supply laterals in the tunnel will be reconnected to the new line. The options for new piping material were stainless steel and HDPE materials. HDPE materials have high thermal expansion rates, requiring additional piping length for loops and making them cost competitive with stainless steel. Stainless steel will keep expansion to a minimum while providing a continuously welded piping system, with the only flanged connections at service laterals and connections to existing piping. The welded stainless steel would eliminate piping joints in this section of the tunnel and eliminate the long-term maintenance needs associated with the piping. ECU has opted for stainless steel. The existing piping will remain active while the new piping is constructed, and shutdowns will be required to switch over to the new piping.

Additional issues were brought up during discussions with medical campus facility staff. They indicated that a new fire service connection for the Leo Jenkins Cancer Center would be necessary to provide adequate fire sprinkling pressure and flows to the additional upper floors. Also mentioned was the need

for a new secure post indicator valve for the line running to Vidant Hospital and the need to replace the water valves and post indicator valve for the Pediatrics/Biotechnology outside vault.

UTILITY CONDITION ASSESSMENT

SECTION 3

CONDITION ASSESSMENT DEFINITIONS

CONDITION ASSESSMENT DEFINITIONS

The following information is a clarification of the Asset Report using example definitions.

Material and Labor Cost Factors and Additional Markups

The database contains an R. S. Means City Cost Index for material and labor cost factors to adjust the project costs from the national averages to reflect conditions in Greenville. The percentage adjustment of the national average is shown below. Typical general contractor fees (which could include profit, overhead, bonds, and insurance) and professional fees (architect or engineer design fees and in-house design costs) are also included. However, most of the project costs were provided by University personnel, so no mark-ups have been applied.

| GLOBAL MARKUP | % |
|---------------------------|-------|
| Local Labor Index | 71.3 |
| Local Materials Index | 100.7 |
| General Contractor Markup | 20.0 |
| Professional Fees | 16.0 |

Recurring and Nonrecurring Renewal Costs

Renewal costs are divided into two main categories – recurring and nonrecurring. Recurring costs are cyclical and consist primarily of major repairs to or replacement/rebuilding of systems and components. The tool for projecting the recurring renewal costs is the Lifecycle Component Inventory, which is explained in detail below. Nonrecurring costs typically consist of modifications or repairs necessary to comply with code requirements or to address isolated, nonrecurring deficiencies that could negatively affect the systems and components. For these nonrecurring costs, projects have been developed and include estimated material and labor costs.

Recurring Costs

Asset Component Inventory and Cost Projections

The Asset Component Inventory is a list of major systems and components and is based on industry standard lifecycle expectancies. Each indicated component has the following associated information:

| CATEGORY | DEFINITION |
|----------------------------|---|
| Uniformat Code | The standard Uniformat Code that applies to the component |
| Component Description | This line item describes the individual component |
| Identifier | Unique identifying information entered for a component as necessary |
| Quantity | The quantity of the listed component |
| Units | The unit of measure associated with the quantity |
| Unit Cost | The cost to replace each individual component unit (this cost is in today's dollars) |
| Complexity Adjustment | A factor utilize to adjust component replacement costs accordingly when it is anticipated that the actual cost will deviate from the average for that component |
| Total Cost | Unit cost multiplied by quantity, in today's dollars. Note that this is a one-time renewal/replacement cost |
| Install Date | Year that the component was or is estimated to have been installed. When this data is not available, it defaults to the year the asset was constructed |
| Life Expectancy | Average life expectancy for each individual component |
| Life Expectancy Adjustment | Utilized to adjust the first lifecycle of the component and to express when the next replacement should occur |

The component listing forms the basis of the Recurring Component Renewal Schedule, which provides a year-by-year list of projected recurring renewal costs over the next ten years. Each individual component is assigned a replacement year based on lifecycles, and the costs for each item are in future year dollars. For items that are already past the end of their lifecycle, the replacement year is shown as Deferred Renewal.

Recurring Cost Classifications

- **Deferred Renewal**
 Recurring repairs, generated by the Asset Component Inventory, that are past due for completion but have not yet been accomplished as part of normal maintenance or capital repair efforts. Further deferral of such renewal could impair the proper functioning of the system. Estimated Deferred Renewal costs should include compliance with applicable codes, even if such compliance requires expenditures beyond those essential to effect the needed repairs.

- **Projected Renewal**
 Recurring renewal efforts, generated by the Asset Component Inventory, that will be due within

the scope of the assessment. These are regular or normal maintenance, repair, or renovation efforts that should be planned in the near future.

Nonrecurring Costs

As previously mentioned, modifications or repairs necessary to comply with code requirements and those that address isolated, nonrecurring deficiencies that could negatively affect the systems and components are not included in the Lifecycle Component Inventory. For each such deficiency, a project with an estimated cost to rectify said deficiency is recommended. These projects each have a unique number and are categorized by system type, priority, and classification, which are defined below. The costs in these projects are also indexed to local conditions and markups applied as the situation dictates.

Project Number

Each project has a unique number consisting of three elements, the asset identification number, system code, and a sequential number assigned by the FCA software. For example, the fourth electrical project identified for asset 0001 would have a project number of 0001EL04:

| Example: Project Number 0001EL04 | | |
|-------------------------------------|---|--|
| 0001 | - | Asset Identification Number |
| EL | - | System Code (EL represents Electrical) |
| 04 | - | The next sequential number for an Electrical project |

Project Classification

- **Plant Adaption**
 Nonrecurring expenditures required to adapt the physical plant to the evolving needs of the institution and to changing codes or standards. These are expenditures beyond normal maintenance. Examples include compliance with changing codes and improvements occasioned by the adoption of modern technology (e.g., the use of personal computer networks).

- **Corrective Action**
 Nonrecurring expenditures for repairs needed to correct random and unpredictable deficiencies. Such projects are not related to aligning a building with codes or standards. Deficiencies classified as Corrective Action could have an effect on utility safety or usability.

Priority Class

- **Immediate**

Projects in this category require immediate action to:

- a. correct a cited safety hazard
- b. stop accelerated deterioration
- c. and/or return a facility to normal operation

- **Critical**

Projects in this category include actions that must be addressed in the short-term:

- a. repairs to prevent further deterioration
- b. improvements to facilities associated with critical accessibility needs
- c. potential safety hazards

- **Noncritical**

Projects in this category include:

- a. improvements to facilities associated with noncritical accessibility needs
- b. actions to bring a facility into compliance with current building codes
- c. actions to improve the usability of a facility following an occupancy or use change

Category Code

| CATEGORY CODE* | SYSTEM DESCRIPTION |
|----------------|--------------------|
| EL1A – EL8A | ELECTRICAL |
| FS1A – FS6A | FIRE/LIFE SAFETY |
| HV1A – HV8B | HVAC |
| PL1A – PL5A | PLUMBING |

| <i>Example:</i> Category Code = EL5A | |
|---|-----------------------|
| EL | System Description |
| 5 | Component Description |
| A | Element Description |

**Refer to the Category Code Report starting on the following page.*

Priority Sequence

A Priority Sequence number is automatically assigned to each project to rank the projects in order of relative criticality and show the recommended execution order. This number is calculated based on the Priority Class and identified system of each project.

| <i>Example:</i> | | | |
|-----------------|---------------|----------------|-------------------|
| Priority Class | Category Code | Project Number | Priority Sequence |
| 1 | HV2C | 0001HV04 | 01 |
| 2 | PL1D | 0001PL02 | 02 |
| 2 | EL4C | 0001EL03 | 03 |

CATEGORY CODE REPORT

| FIRE/LIFE SAFETY | | | |
|------------------|-----------------------|------------------------------|--|
| CODE | COMPONENT DESCRIPTION | ELEMENT DESCRIPTION | DEFINITION |
| FS1A | Lighting | Egress Lighting/Exit Signage | R&R work on exit signage and packaged AC/DC emergency lighting. |
| FS2A | Detection/Alarm | General | Repair or replacement of fire alarm/detection system/components, including alarms, pull boxes, smoke/heat detectors, annunciator panels, central fire control stations, remote dialers, fire station communications, etc. |
| FS3A | Suppression | Sprinklers | Repair or installation of water sprinkler type automatic fire suppressions, including wet-pipe and dry-pipe systems, heads, piping, deflectors, valves, monitors, associated fire pump, etc. |
| FS3B | Suppression | Standpipe/Hose | Repair or installation of standpipe system or components, including hardware, hoses, cabinets, nozzles, necessary fire pumping system, etc. |
| FS3C | Suppression | Extinguishers | Repairs or upgrades to F.E. cabinets/wall fastenings and handheld extinguisher testing/replacement. |
| FS3D | Suppression | Other | Other fire suppression items not specifically categorized elsewhere, including fire blankets, carbon dioxide automatic systems, Halon systems, dry chemical systems, etc. |
| FS4A | Hazardous Materials | Storage Environment | Installation or repair of special storage environment for the safe holding of flammable or otherwise dangerous materials/supplies, including vented flammables storage cabinets, holding pens/rooms, cages, fire safe chemical storage rooms, etc. |
| FS4B | Hazardous Materials | User Safety | Improvements, repairs, installation, or testing of user safety equipment, including emergency eyewashes, safety showers, emergency panic/shut-down system, etc. |
| FS5A | Egress Path | Designation | Installation, relocation or repair of posted diagrammatic emergency evacuation routes. |
| FS5B | Egress Path | Distance/Geometry | Work involving remediation of egress routing problems, including elimination of dead end corridors, excessive egress distance modifications, and egress routing inadequacies. |
| FS5C | Egress Path | Separation Rating | Restoration of required fire protective barriers, including wall rating compromises, fire-rated construction, structural fire proofing, wind/safety glazing, transom retrofitting, etc. |
| FS5D | Egress Path | Obstruction | Clearance of items restricting the required egress routes. |
| FS5E | Egress Path | Stairs Railing | Retrofit of stair/landing configurations/structure, railing heights/geometries, etc. |
| FS5F | Egress Path | Fire Doors/Hardware | Installation/replacement/repair of fire doors and hardware, including labeled fire doors, fire shutters, closers, magnetic holders, panic hardware, etc. |
| FS5G | Egress Path | Finish/Furniture Ratings | Remediation of improper fire/smoke ratings of finishes and furniture along egress routes. |
| FS6A | General | Other | Life/fire safety items not specifically categorized elsewhere. |

| PLUMBING | | | |
|----------|-----------------------|---------------------|---|
| CODE | COMPONENT DESCRIPTION | ELEMENT DESCRIPTION | DEFINITION |
| PL1A | Domestic Water | Piping Network | Repair or replacement of domestic water supply piping network, insulation, hangers, etc. |
| PL1B | Domestic Water | Pumps | Domestic water booster pumps, circulating pumps, related controls, etc. |
| PL1C | Domestic Water | Storage/Treatment | Equipment or vessels for storage or treatment of domestic water. |
| PL1D | Domestic Water | Metering | Installation, repair, or replacement of water meters. |
| PL1E | Domestic Water | Heating | Domestic water heaters, including gas, oil, and electric water heaters, shell-and-tube heat exchangers, tank type, and instantaneous. |
| PL1F | Domestic Water | Cooling | Central systems for cooling and distributing drinking water. |
| PL1G | Domestic Water | Fixtures | Plumbing fixtures, including sinks, drinking fountains, water closets, urinals, etc. |

| | | | |
|------|-----------------|---|--|
| PL1H | Domestic Water | Conservation | Alternations made to the water distribution system to conserve water. |
| PL1I | Domestic Water | Backflow Protection | Backflow protection devices, including backflow preventers, vacuum breakers, etc. |
| PL2A | Wastewater | Piping Network | Repair or replacement of building wastewater piping network. |
| PL2B | Wastewater | Pumps | Pump systems used to lift wastewater, including sewage ejectors and other sump systems. |
| PL3A | Special Systems | Process Gas/Fluids | Generation and/or distribution of process steam, compressed air, natural and LP gas, process water, vacuum, etc. |
| PL4A | Infrastructure | Potable Water Storage/ Treatment | Storage and treatment of potable water for distribution. |
| PL4B | Infrastructure | Industrial Water Distribution/ Treatment | Storage and treatment of industrial water for distribution. |
| PL4C | Infrastructure | Sanitary Water Collection | Sanitary water collection systems and sanitary sewer systems, including combined systems. |
| PL4D | Infrastructure | Stormwater Collection | Stormwater collection systems and storm sewer systems; stormwater only. |
| PL4E | Infrastructure | Potable Water Distribution | Potable water distribution network. |
| PL4F | Infrastructure | Wastewater Treatment | Wastewater treatment plants, associated equipment, etc. |
| PL5A | General | Other | Plumbing issues not categorized elsewhere. |

UTILITY CONDITION ASSESSMENT

SECTION 4

COST SUMMARIES AND TOTALS

RENEWAL COSTS MATRIX

All dollars shown as Present Value

| CATEGORY | NONRECURRING PROJECT NEEDS | | | RECURRING COMPONENT REPLACEMENT NEEDS | | | | | | | | | | | |
|---|----------------------------|------------------|------------------|--|------------|------------|------------|-----------------|------------|------------|------------|------------|------------------|------------------|------------------|
| | Immediate | Critical | Noncritical | Deferred Renewal | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | TOTAL |
| ACCESSIBILITY | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | \$0 |
| EXTERIOR | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | \$0 |
| INTERIOR | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | \$0 |
| PLUMBING | 0 | 292,547 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 350,162 | 0 | \$642,708 |
| HVAC | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | \$0 |
| FIRE/LIFE SAFETY | 0 | 49,931 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | \$49,931 |
| ELECTRICAL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 11,103 | 0 | 0 | 0 | 0 | 0 | 0 | \$11,103 |
| SITE | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | \$0 |
| VERT. TRANS. | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | \$0 |
| HEALTH/EQUIP. | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | \$0 |
| SUBTOTAL | \$0 | \$342,478 | \$0 | \$0 | \$0 | \$0 | \$0 | \$11,103 | \$0 | \$0 | \$0 | \$0 | \$350,162 | \$0 | \$703,743 |
| TOTAL NONRECURRING PROJECT NEEDS | | | \$342,478 | TOTAL RECURRING COMPONENT REPLACEMENT NEEDS | | | | | | | | | | \$361,265 | |

| | |
|---------------------------------------|--------------------|
| CURRENT REPLACEMENT VALUE | \$1,700,000 |
| FACILITY CONDITION NEEDS INDEX | 0.41 |
| FACILITY CONDITION INDEX | 0.00 |

| | | |
|------------|---|-------------------------|
| GSF | TOTAL 10-YEAR FACILITY RENEWAL NEEDS | 10-YEAR NEEDS/SF |
| NA | \$703,743 | NA |

FACILITIES RENEWAL PLAN
NONRECURRING PROJECT COSTS

All costs shown as Present Value

| PROJECT NUMBER | PROJECT TITLE | UNI-FORMAT | PRIORITY CLASS | PROJECT CLASSIFICATION | PROJECT COST |
|----------------|---|------------|----------------|------------------------|------------------|
| HSPWFPL01 | REPLACE ORIGINAL POTABLE WATER PIPE IN UTILITY TUNNEL | | 2 | Corrective Action | 211,204 |
| HSPWFPS01 | PROVIDE NEW FIRE SERVICE FOR LEO JENKINS BLDG | | 2 | Plant Adaption | 49,931 |
| HSPWFPL02 | INSTALL NEW POST INDICATOR VALVE FOR LINE TO VIDANT | | 2 | Plant Adaption | 11,562 |
| HSPWFPL03 | NEW VALVES AND PIV - PEDIATRICS/BIOTECHNOLOGY OUTSIDE VAULT | | 2 | Capital Renewal | 69,781 |
| TOTAL | | | | | \$342,478 |

FACILITIES RENEWAL PLAN
RECURRING COMPONENT REPLACEMENT COSTS

All costs shown as Present Value

| ASSET CODE COMP CODE | COMPONENT | IDENTIFIER | UNI- FORMAT | REPLACEMENT YEAR | REPLACEMENT COST |
|-------------------------|-------------------------------------|------------|----------------|---------------------|---------------------|
| HSPWFP VF04 | VARIABLE FREQUENCY DRIVE (10-15 HP) | VSD-DWP1 | D5010 | 2020 | 5,552 |
| HSPWFP VF04 | VARIABLE FREQUENCY DRIVE (10-15 HP) | VSD-DWP2 | D5010 | 2020 | 5,552 |
| HSPWFP PP01 | DOMESTIC WATER BOOSTER SYSTEM | ROOM 113 | D2020 | 2025 | 350,162 |
| TOTAL | | | | | \$361,265 |

UTILITY CONDITION ASSESSMENT

SECTION 5

PROJECT DETAILS

All costs shown as Present Value

| PROVIDE NEW FIRE SERVICE FOR LEO JENKINS BLDG | | | |
|---|----------------|-----------------------|------------------|
| Project Number: | HSPWFPS01 | Category Code: | |
| Priority Sequence: | 1 | FS3D | |
| Priority Class: | Critical | System: | FIRE/LIFE SAFETY |
| Project Class: | Plant Adaption | Component: | SUPPRESSION |
| Date Basis: | 4/4/2017 | Element: | OTHER |

| Code Application: | Subclass/Savings: | Project Location: |
|-------------------|-------------------|-----------------------|
| NFPA | Not Applicable | Undefined: Floor(s) S |

Description

Medical campus facility staff indicated that a new fire service connection is needed for the Leo Jenkins Cancer Center. The new service is required to provide adequate fire sprinkling pressure and flows to the additional upper floors.

All costs shown as Present Value

Project Cost Estimate

| Task Description | Unit | Qty | Material Unit Cost | Total Material Cost | Labor Unit Cost | Total Labor Cost | Total Cost |
|--|----------|-----|--------------------|---------------------|-----------------|------------------|-----------------|
| Add new fire service with larger capacity | LOT | 1 | \$25,000 | \$25,000 | \$15,000 | \$15,000 | \$40,000 |
| Base Material/Labor Costs | | | | \$25,000 | | \$15,000 | |
| Indexed Material/Labor Costs | | | | \$25,175 | | \$10,695 | \$35,870 |
| General Contractor Mark Up at 20.0% | | | | | | | \$7,174 |
| Original Construction Cost | | | | | | | \$43,044 |
| Date of Original Estimate: | 4/4/2017 | | | | | Inflation | \$0 |
| Current Year Construction Cost | | | | | | | \$43,044 |
| Professional Fees at 16.0% | | | | | | | \$6,887 |
| TOTAL PROJECT COST | | | | | | | \$49,931 |

All costs shown as Present Value

| REPLACE ORIGINAL POTABLE WATER PIPE IN UTILITY TUNNEL | | | |
|---|-------------------|-----------------------|----------------------|
| Project Number: | HSPWFPPLO1 | Category Code: | |
| Priority Sequence: | 2 | PL4E | |
| Priority Class: | Critical | System: | PLUMBING |
| Project Class: | Corrective Action | Component: | INFRASTRUCTURE |
| Date Basis: | 4/4/2017 | Element: | POTABLE WATER DISTR. |

| Code Application: | Subclass/Savings: | Project Location: |
|-------------------|-------------------|-----------------------|
| Not Applicable | Not Applicable | Item Only: Floor(s) S |

Description

Replace the first 350 feet of original water piping with a new domestic water pipe routed above the existing chilled water piping in the tunnel. The new line would be constructed in the original section of the tunnel and replace all of the existing domestic water piping with mechanical joint fittings. The existing supply laterals in the tunnel would be reconnected to the new line.

All costs shown as Present Value

Project Cost Estimate

| Task Description | Unit | Qty | Material Unit Cost | Total Material Cost | Labor Unit Cost | Total Labor Cost | Total Cost |
|--|----------|-----|--------------------|---------------------|-----------------|------------------|------------------|
| Replace tunnel domestic water pipe | LF | 375 | \$200 | \$75,000 | \$285 | \$106,875 | \$181,875 |
| Base Material/Labor Costs | | | | \$75,000 | | \$106,875 | |
| Indexed Material/Labor Costs | | | | \$75,525 | | \$76,202 | \$151,727 |
| General Contractor Mark Up at 20.0% | | | | | | | \$30,345 |
| Original Construction Cost | | | | | | | \$182,072 |
| Date of Original Estimate: | 4/4/2017 | | | | | Inflation | \$0 |
| Current Year Construction Cost | | | | | | | \$182,072 |
| Professional Fees at 16.0% | | | | | | | \$29,132 |
| TOTAL PROJECT COST | | | | | | | \$211,204 |

All costs shown as Present Value

| INSTALL NEW POST INDICATOR VALVE FOR LINE TO VIDANT | | | |
|---|----------------|-----------------------|----------------------|
| Project Number: | HSPWFPPLO2 | Category Code: | |
| Priority Sequence: | 3 | PL4E | |
| Priority Class: | Critical | System: | PLUMBING |
| Project Class: | Plant Adaption | Component: | INFRASTRUCTURE |
| Date Basis: | 4/4/2017 | Element: | POTABLE WATER DISTR. |

| Code Application: | Subclass/Savings: | Project Location: |
|-------------------|-------------------|-----------------------|
| Not Applicable | Not Applicable | Undefined: Floor(s) S |

Description

Medical campus facility staff indicated that a new secure post indicator valve would be needed for the line running to Vidant Hospital.

All costs shown as Present Value

Project Cost Estimate

| Task Description | Unit | Qty | Material Unit Cost | Total Material Cost | Labor Unit Cost | Total Labor Cost | Total Cost |
|--|----------|-----|--------------------|---------------------|-----------------|------------------|-----------------|
| Install a new post indicator valve | EA | 1 | \$4,000 | \$4,000 | \$6,000 | \$6,000 | \$10,000 |
| Base Material/Labor Costs | | | | \$4,000 | | \$6,000 | |
| Indexed Material/Labor Costs | | | | \$4,028 | | \$4,278 | \$8,306 |
| General Contractor Mark Up at 20.0% | | | | | | | \$1,661 |
| Original Construction Cost | | | | | | | \$9,967 |
| Date of Original Estimate: | 4/4/2017 | | | | | Inflation | \$0 |
| Current Year Construction Cost | | | | | | | \$9,967 |
| Professional Fees at 16.0% | | | | | | | \$1,595 |
| TOTAL PROJECT COST | | | | | | | \$11,562 |

All costs shown as Present Value

| NEW VALVES AND PIV - PEDIATRICS/BIOTECHNOLOGY OUTSIDE VAULT | | | |
|---|-----------------|-----------------------|----------------------|
| Project Number: | HSPWFPL03 | Category Code: | |
| Priority Sequence: | 4 | PL4E | |
| Priority Class: | Critical | System: | PLUMBING |
| Project Class: | Capital Renewal | Component: | INFRASTRUCTURE |
| Date Basis: | 4/4/2017 | Element: | POTABLE WATER DISTR. |

Code Application:

Not Applicable

Subclass/Savings:

Not Applicable

Project Location:

Undefined: Floor(s) S

Description

Medical campus facility staff indicated that the water valves and post indicator valve for the Pediatrics/Biotechnology outside vault would need to be replaced in the next ten years.

All costs shown as Present Value

Project Cost Estimate

| Task Description | Unit | Qty | Material Unit Cost | Total Material Cost | Labor Unit Cost | Total Labor Cost | Total Cost |
|---|----------|-----|--------------------|---------------------|-----------------|------------------|-----------------|
| Replace the PIV and water valves in outside vault | LOT | 1 | \$25,000 | \$25,000 | \$35,000 | \$35,000 | \$60,000 |
| Base Material/Labor Costs | | | | \$25,000 | | \$35,000 | |
| Indexed Material/Labor Costs | | | | \$25,175 | | \$24,955 | \$50,130 |
| General Contractor Mark Up at 20.0% | | | | | | | \$10,026 |
| Original Construction Cost | | | | | | | \$60,156 |
| Date of Original Estimate: | 4/4/2017 | | | | | Inflation | \$0 |
| Current Year Construction Cost | | | | | | | \$60,156 |
| Professional Fees at 16.0% | | | | | | | \$9,625 |
| TOTAL PROJECT COST | | | | | | | \$69,781 |

UTILITY CONDITION ASSESSMENT

SECTION 6

ASSET COMPONENT INVENTORY

ASSET COMPONENT INVENTORY

| UNI-FORMAT | COMPONENT DESCRIPTION | IDENTIFIER | QTY | UNITS | UNIT COST | CMPLX ADJ | TOTAL COST | INSTALL DATE | USEFUL LIFE | USEFUL LIFE ADJ |
|------------|--|----------------------|-----|-------|-------------|-----------|------------|--------------|-------------|-----------------|
| D2020 | DOMESTIC WATER BOOSTER SYSTEM | ROOM 113 | 30 | HP | \$11,672.06 | | \$350,162 | 2005 | 20 | |
| D4010 | FIRE PUMP - ELECTRIC, 250 GPM, 2" ID (<=15 HP) | FP2 | 3 | HP | \$2,412.79 | | \$7,238 | 2005 | 25 | |
| D4010 | FIRE PUMP - ELECTRIC, 1000 GPM, 5" ID (120-150 HP) | CUP RM 113 | 125 | HP | \$513.77 | | \$64,221 | 2005 | 25 | |
| D5010 | VARIABLE FREQUENCY DRIVE (10-15 HP) | VSD-DWP1 | 15 | HP | \$370.11 | | \$5,552 | 2005 | 12 | 3 |
| D5010 | VARIABLE FREQUENCY DRIVE (10-15 HP) | VSD-DWP2 | 15 | HP | \$370.11 | | \$5,552 | 2005 | 12 | 3 |
| G3010 | FIRE HYDRANT | | 2 | EA | \$8,684.81 | | \$17,370 | 1980 | 65 | |
| G3010 | FIRE HYDRANT | | 8 | EA | \$8,684.81 | | \$69,478 | 2010 | 65 | |
| G3010 | DUCTILE IRON PIPE - 6" DIAMETER - SUPPLY | FIRE PROTECTION | 445 | LF | \$146.19 | | \$65,053 | 2000 | 75 | |
| G3010 | DUCTILE IRON PIPE - 6" DIAMETER - SUPPLY | POTABLE WATER | 870 | LF | \$146.19 | | \$127,182 | 1980 | 75 | |
| G3010 | DUCTILE IRON PIPE - 6" DIAMETER - SUPPLY | POTABLE WATER | 100 | LF | \$146.19 | | \$14,619 | 2000 | 75 | |
| G3010 | DUCTILE IRON PIPE - 8" DIAMETER - SUPPLY | POTABLE WATER | 75 | LF | \$155.61 | | \$11,671 | 1980 | 75 | |
| G3010 | DUCTILE IRON PIPE - 8" DIAMETER - SUPPLY | FIRE PROTECTION, PVC | 665 | LF | \$155.61 | | \$103,482 | 1980 | 75 | |
| G3010 | DUCTILE IRON PIPE - 8" DIAMETER - SUPPLY | FIRE PROTECTION | 640 | LF | \$155.61 | | \$99,592 | 1980 | 75 | |
| G3010 | DUCTILE IRON PIPE - 8" DIAMETER - SUPPLY | FIRE PROTECTION | 660 | LF | \$155.61 | | \$102,704 | 2000 | 75 | |
| G3010 | DUCTILE IRON PIPE - 8" DIAMETER - SUPPLY | FIRE PROTECTION | 400 | LF | \$155.61 | | \$62,245 | 2010 | 75 | |
| G3010 | DUCTILE IRON PIPE - 10" DIAMETER - SUPPLY | FIRE PROTECTION | 770 | LF | \$163.11 | | \$125,598 | 1980 | 75 | |

ASSET COMPONENT INVENTORY

| UNI-FORMAT | COMPONENT DESCRIPTION | IDENTIFIER | QTY | UNITS | UNIT COST | CMPLX ADJ | TOTAL COST | INSTALL DATE | USEFUL LIFE | USEFUL LIFE ADJ |
|---------------------|---|-----------------|-------|-------|-----------|-----------|--------------------|--------------|-------------|-----------------|
| G3010 | DUCTILE IRON PIPE - 10" DIAMETER - SUPPLY | FIRE PROTECTION | 80 | LF | \$163.11 | | \$13,049 | 2000 | 75 | |
| G3010 | DUCTILE IRON PIPE - 10" DIAMETER - SUPPLY | POTABLE WATER | 80 | LF | \$163.11 | | \$13,049 | 1980 | 75 | |
| G3010 | PVC PLASTIC PIPE - 4" DIAMETER | POTABLE WATER | 2,600 | LF | \$107.75 | | \$280,146 | 1980 | 50 | |
| G3010 | PVC PLASTIC PIPE - 4" DIAMETER | POTABLE WATER | 170 | LF | \$107.75 | | \$18,317 | 2000 | 50 | |
| G3010 | PVC PLASTIC PIPE - 4" DIAMETER | POTABLE WATER | 1,100 | LF | \$107.75 | | \$118,523 | 2010 | 50 | |
| Grand Total: | | | | | | | \$1,674,802 | | | |

UTILITY CONDITION ASSESSMENT

SECTION 7

SYSTEM PHOTOLOG



HSPWFP001e 3/8/2017
Older fire hydrant
Campus grounds



HSPWFP002e 3/8/2017
City-owned 15 inch ductile iron pipe crossing creek
South side of West 5th Street



HSPWFP003e 3/8/2017
Older fire hydrant
Campus grounds



HSPWFP004e 3/8/2017
Older fire hydrant
Campus grounds



HSPWFP005e 3/8/2017
Older fire hydrant
Campus grounds



HSPWFP006e 3/8/2017
Older fire hydrant
Campus grounds



HSPWFP007e

Older fire hydrant
Campus grounds

3/8/2017



HSPWFP008e

Older fire hydrant
Campus grounds

3/8/2017



HSPWFP009e

Older fire hydrant
Campus grounds

3/8/2017



HSPWFP010e

Older fire hydrant
Campus grounds

3/8/2017



HSPWFP011e

125 hp fire pump
Central Plant

3/8/2017



HSPWFP012e

Electric fire pump controller
Central Plant


3/8/2017



HSPWFP013e 3/8/2017
125 hp fire pump set-up
Central Plant



HSPWFP014e 3/8/2017
Inline centrifugal pump
Central Plant



HSPWFP015e 3/8/2017
Inline centrifugal pump
Central Plant



HSPWFP016e 3/8/2017
125 hp fire pump set-up
Central Plant



HSPWFP017e 3/8/2017
Older fire hydrant
Campus grounds



HSPWFP018e 3/8/2017
Older fire hydrant
Campus grounds



HSPWFP019e 3/8/2017
Older fire hydrant
Campus grounds



HSPWFP020e 3/8/2017
Older hydrant and new FDC
Family Medicine



HSPWFP021e 3/8/2017
Older fire hydrant
Campus grounds



HSPWFP022e 3/8/2017
Other side of fire hydrant in photo 21e
Campus grounds